



CITY OF ALBANY
DEPARTMENT OF FIRE AND EMERGENCY SERVICES
26 BROAD STREET
ALBANY, NEW YORK 12202
TELEPHONE (518) 447-7879
FAX (518) 447-7883



JOSEPH W. GREGORY
CHIEF OF DEPARTMENT

Mr. Brad Glass
Albany Planning Director
200 Henry Johnson Blvd
First Floor, Suite 3
Albany, New York 12210

August 27, 2021

Re: 1053 Broadway

Dear Brad,

In reviewing the most recent plans for the outdoor deck at 1053 Broadway, the Fire Department has several concerns. The main gas connect to the building is on the Bridge St side of the building and would need to be moved for our access, but there is no design on how this will occur. Also, the Fire Department connection is along the north wall and there is no design for where this will be relocated if the new deck is installed. Finally, due to the size of Bridge St, we would request that Bridge St does not allow any parking on either side of the street from Broadway to Mill St.

Sincerely,

Joseph W. Gregory
Chief of the Department