



KATHY SHEEHAN
MAYOR

CITY OF ALBANY
POLICE DEPARTMENT
TRAFFIC ENGINEERING DIVISION
10 N ENTERPRISE DRIVE
ALBANY, NEW YORK 12204
TELEPHONE: (518) 434-5791
FAX: (518) 434-4315

ERIC HAWKINS
CHIEF OF POLICE

August 27, 2021

Bradley Glass
Planning Director
Albany Planning Department
200 Henry Johnson Boulevard
First Floor, Suite 3
Albany, New York 12210

RE: 1053 Broadway, Druthers proposed deck

Mr. Glass,


We have reviewed the most recent documents in reference to the outdoor deck proposal for the Bridge St side of 1053 Broadway and are submitting the following comments/concerns/observations:

Comments/Concerns

- At the eastern most end it appears that the deck will limit the view (sight distance) from a vehicle exiting the driveway from Surpass Chemical looking to the west for oncoming eastbound vehicle and pedestrian traffic.
- Also at the eastern most end, the deck could limit the view (sight distance) for pedestrians on the south side of Bridge St to view vehicles exiting Surpass Chemical.
- Delivery vehicle locations area not shown on the plans but should be noted on where deliveries are made.
- DGS Engineering Division should verify the curb and sidewalk details shown on the plans to assure compliance with City specifications
- Plans note a deviation from the twenty-four foot width of street. No reduction in width of the roadway is permitted

Should you have any questions regarding our comments/concerns or observations, please contact me at your convenience.

Sincerely,


William Trudeau Jr.
Chief Supervisor of Traffic Engineering
Albany Police Department